




Second Euro-mediterranean **Rendez-vous on Energy**

January 6th 2015
European Parliament, Brussels



Which interconnections can be envisaged by 2020? Western corridor: Maghreb -Iberia

M. Rivier, A. Ramos, L. Olmos, F. M. Echavarren, L. Rouco
Universidad Pontificia Comillas

J. Dubois, V. Lambillon, L. Rese
Tractebel Engineering



OBJECTIVES & METHODOLOGY

→ Objectives


- To assess the grid investment costs for Western Corridor:
 - transit from Maghreb (MA) (Morocco and Algeria) towards France through the Iberian Peninsula (IB)
 - associated to an increase of +1GW, +2GW, +3GW
- Additional sensitivity analysis for North to South analysis

→ Similar to the Central Corridor one:

- Existing AC link between Morocco and Spain => N-1 rules are different

Exchange Scenarios South to North


SP-FR INTERCONNECTION



Routes	Length (km)	
	Total	Submarine
Vandellós - Aramon Gatica - Cordemais	540	500

Technology	Invest Costs M€
1GW 500kV HVDC LCC bipolar return cable	871

MAGHREB – IBERIAN PENINSULA INTERCONNECTION OPTIONS (LINKS AND CONNECTIONS POINTS ANALYSED)



ANALYZED OPTIONS: EXCHANGE SCENARIOS / TECHNICAL OPTIONS

- 16 **IB-MA Exchange Scenarios** to cover a wide range of possibilities.
 - For each one, 2 PT-SP exchange scenarios +-2.5 GW
- For each one, different **Technical Solutions** (up to 39) are envisaged.
- 2 **variants** (Puerto de la Cruz and Cabra for MO-SP HVDC link)

Transit level	+1GW			+2GW					+3GW							
Exchange Scenario (XS) #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	Targeted exchange capacity [GW]															
MO-SP	1			2	2	1	1	1	3	2	2	2	1	1	1	1
MO-PT		1				1	1			1	1				1	1
DZ-SP			1					1				1	2	2	1	1
	Location Extra Production [GW]															
G _{MO}	1	1		2	1	2	1	1	3	3	2	2	1	2	2	1
G _{DZ}			1		1		1	1			1	1	2	1	1	2

Assessment of Technical Options for each Exchange Scenario

South to North

Sc	Description	Investment Costs M€	
3A (***)	DZ-SP: Invest 1GW HVDC 500kV LCC bipolar link	SP-FR 871	DZ-SP 565
		DZ 4	1440

LCC bipolar

+1 GW S to N

+1GW

+1G



Sc	Description	Invest. Costs M€	
1A (*)	MO-SP: Use the current 2x700 MVA AC lines	SP-FR 871	MO 118
		SP 117	(#) 0
		1106	
		(##) 989	
1B (**)	MO-SP: Invest 1x700MWVA 400kV AC line	SP-FR 871	MO 118
		MO-SP 135	SP 117
		1241	
1C (***)	MO-SP: Invest 1GW HVDC 400kV LCC bipolar link	SP-FR 871	MO 118
		MO-SP 193	SP 117
		1299	
Sc	Description	Invest. Costs M€	
2A (***)	MO-PT: Invest 1GW HVDC 500kV LCC bipolar link	SP-FR 871	MO-PT 478
		PT 71	SP 5
		MO 118	
		1543	

(*) Gen. tripping of 300MW for NTC 1GW (100 instant. + 200 in 20mn)
 (#) NTC 0.7GW. No tripping needed.
 (**) MA-IB 1.4-1.8 GW (NTC only wrt interconnections)
 (***) MA-IB 1.7-1.9 GW (NTC only wrt interconnections)
 VSC-BIP (1A+86; 1B+86; 1C+142; 2A+175; 3A+172) M€
 No return cable (1A -140; 1B -140; 1C -146; 2A -200; 3A -217) M€


(*) Gen. tripping of 600MW for NTC 2GW
(200MW inst. + 400MW in 20 mn)

(**) Gen. tripping of 300MW for NTC 2GW
(100MW inst. + 200MW in 20 mn)

(+) MA-IB 2.5-3.0 GW (NTC only wrt
interconnections)


VSC-BIP (A+172; B+344; C+228; D+430) M€

No R.Cab. (A-279; B-290; C-285; D-279) M€




Sc	Description	Investment Costs M€		
		Sc 4	Sc 5	
4A 5A (*)	MO-SP: Invest 1x700MW AC additional line	SP-FR	1742	
		MO-SP	135	
		MO+DZ	550+0	389+4
		SP	117	
		2544	2387	
4B 5B	MO-SP: Convert 2x700 MW AC in 1x700 MW AC + 2GW 500 kV HVDC LCC bipolar	SP-FR	1742	
		MO-SP	321	
		MO+DZ	550+0	389+4
		SP	117	
		2730	2573	
4C 5C (**)	MO-SP: Invest 1GW 400kV HVDC LCC bipolar link	SP-FR	1742	
		MO-SP	193	
		MO+DZ	550+0	389+4
		SP	117	
		2602	2445	
4D 5D (+)	MO-SP: Convert 2x700 MW AC in 3GW 500kV HVDC LCC bipolar	SP-FR	1742	
		MO-SP	465	
		MO+DZ	550+0	389+4
		SP	117	
		2874	2717	

(*) Gen. tripp. of 300MW for NTC 2GW
(100MW inst. + 200MW in 20 mn)
(#) NTC 1.7GW & 500MW inst gen.
tripp.
(+) MA-IB 2.4-2.8 GW (NTC only wrt
interconnections)
VSC-BIP (A+261 ;B+261) M€
No Return Cable. (A-339; B-339) M€



Sc	Description	Investment Costs M€		
		Sc 6	Sc 7	
6A	MO-SP: use current (*) 2x700MW AC MO-PT: invest 1GW 500kV HVDC LCC bipolar link	SP-FR	1742	
7A		MO-PT	478	
(*)		MO+DZ	550+0	389+4
		PT	71	
		SP	123	(#) 5
			2964	2807
		(#)2846	(#)2689	
6B	MO-SP: Invest 7B 1x700MW AC (+) additional line 2x700MW AC MO-PT: invest 1GW 500kV HVDC LCC bipolar link	SP-FR	1742	
		MO-PT	478	
		MO-SP	135	
		MO+DZ	550+0	389+4
		PT	71	
		SP	123	
		3099	2942	

(*) Gen. tripp. of 300MW for NTC 2GW
 (100MW inst. + 200MW in 20 mn)
 (#) NTC 1.7GW + 500MW inst gen. tripp.
 (+) MA-IB 2.4-2.8 GW (NTC only wrt
 interconnections)
 VSC-BIP (A+258; B+258) M€
 No Return Cable. (A-357; B-357) M€



Sc	Description	Investment Costs M€	
8A (*)	MO-SP: use current 2x700MW AC DZ-SP: invest 1GW HVDC 500kV LCC bipolar link	SP-FR	1742
		DZ-SP	565
		MO+DZ	118+4
		SP	117 (#) 0
		2546 (#) 2429	
8B (+)	MO-SP: Invest 1x700MW AC additional line DZ-SP: invest 1GW HVDC 500kV LCC bipolar link	SP-FR	1742
		DZ-SP	565
		MO-SP	135
		MO+DZ	118+4
		SP	117
2681			

North to South transit

METHODOLOGY – NORTH TO SOUTH

→ Total investment costs assessment for a **+2GW** NtoS transit level.

- During course of the project, it appears that most probably flows will first be North to South
- From technical point of view, it was checked:
 - Internal reinforcements identified within SP and PT needed for a StN allow NtS flow
 - The level of investment required in Morocco and Algeria.
- Decoupled from the SP-FR interconnection, so that the investment costs associated to that link are not included in the main results.


(*) Gen. tripping of 600 MW for NTC 2 GW
(200MW inst. + 400MW in 20 mn)

(**) Gen. tripping of 300 MW for NTC 2 GW
(100MW inst. + 200MW in 20 mn)

(+) IB-MA 2.5-3.0 GW (NTC only wrt
interconnections)

VSC-BIP (B+172; C+56; D+258) M€

No R.Cab. (B-11; C-7; D-0) M€



Sc	Description	Investment Costs M€	
		Sc 2-4	Sc 2-5
2-4A	MO-SP: Invest 1x700MW AC additional line (*)	MO-SP	135
2-5A		MO	64
		SP	117
		316	430
2-4B	MO-SP: Convert 2x700 MW AC in 1x700 MW AC + 2GW 500kV HVDC LCC bipolar	MO-SP	321
2-5B		MO	64
		SP	117
		502	616
2-4C	MO-SP: Invest 1GW 400kV HVDC LCC bipolar link (*)	MO-SP	193
2-5C		MO	64
		SP	117
		374	488
2-4D	MO-SP: Convert 2x700 MW AC in 3GW 500kV HVDC LCC bipolar (+)	MO-SP	465
2-5D		MO	64
		SP	117
		646	760


(*). Gen. tripping of 300MW for NTC 2GW
(100MW inst. + 200MW in 20 mn)

(#) NTC 1.7GW & 500MW inst gen. trip.

(+) IB-MA 2.4-2.8 GW (NTC only wrt
interconnections)

VSC-BIP (A+89;B+89) M€

No Return Cable. (A-61; B-61) M€



Sc	Description	Investment Costs M€	
2-6A	MO-SP: use current 2x700MW AC MO-PT: invest 1GW 500kV HVDC link LCC bipolar	MO-PT	478
2-7A		MO	64 178
(*)		PT	71
		SP	123 (#) 5
			736 850 (#) 618 (#) 732
2-6B	MO-SP: Invest 1x700MW AC additional line 2x700MW AC MO-PT: invest 1GW 500kV HVDC link LCC bipolar	MO-PT	478
2-7B		MO-SP	135
(+)		MO	64 178
		PT	71
		SP	123
		871 985	

CONCLUSIONS

SOUTH TO NORTH (i)

- The **majority of investment costs** (870M€ per GW) correspond to the **SP-FR link**
 - long distance HVDC submarine links have been considered.
- The internal grid reinforcement needs are
 - Relatively **small in SP**: 120M€(1&2GW)-160M€(3GW)
 - Relatively **small in PT**: 70M€ (scenarios with 1GW through PT)
 - Quite **large in MO**: 120M€ (1GW), 389-650M€ (2GW), 784-966M€ (3GW)
 - Large flows from the South-Western part to the Northern part.
 - Almost **non existent in DZ**: 4M€
- In terms of total network investments, the **MO-SP interconnection corridor is the less costly option.**
 - Expected due to its shorter length.
 - Converting the current AC ones into HVDC links raise the issue of synchronism between EU and Maghreb.

SOUTH TO NORTH (ii)

- DZ-SP interconnection link is the most expensive one, closely followed by the MO-PT one.
 - **MO-PT advantage:** interconnection will not need to cross areas where the sea depth is above 500m, while the DZ-SP one needs to cross some areas where the sea-depth is above 1500m.
 - **DZ-SP advantage:** no internal grid reinforcements required neither in SP nor in DZ, making it, overall, less costly (in terms of total network investment costs) than the MO-PT interconnection option (this is no longer true if part of the internal network reinforcements in Morocco are not associated to the transit).
- **Costs** computed for solutions analyzed are **very much conditioned by** the size of internal grid **reinforcements required in MO**.
- **N-1 criteria** and automatic tripping mechanisms associated to interconnection failures, **heavily condition the network investment needs** to reach the targeted transit levels.

NORTH TO SOUTH

- The uncoupling with the FR-SP interconnection reduces very much the network investment costs
- Total network investment costs when power imported is consumed both in MO (+1GW) and in DZ (+1GW) are about
 - 500 M€ when using only the MO-SP interconnection
 - 730 M€ when using both the MO-SP interconnection and the MO-PT one.
- If all power imported from SP and PT is consumed in MO (+2GW), the cost of reinforcements decreases in about 110 M€
 - the internal MO grid corridor connecting MO to DZ should not be reinforced.